

APPROVAL FOR CONSTRUCTION

N.H. DEPARTMENT OF ENVIRONMENTAL SERVICES
WATER SUPPLY & POLLUTION CONTROL DIVISION
P.O. BOX 95, 6 HAZEN DRIVE, CONCORD, NH 03301

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR: DIVISION

OWNER:

ARMAND J. ROY
PO BOX 563
EXETER, NH 03833

APPROVAL NO. 168354

Lot Numbers: 2

Subd. Appl. No.:

Subd. Name:

GLORIA L. EVANS

Type of System:

3BR
450GPD

COPY OF PLAN & APPROVAL SENT TO:

TOWN OF KENSINGTON
RFD 2
KENSINGTON, NH 03833

Town/City Location:

KENSINGTON

Street Location:

ROUTE 150

BY APPLICANT: PERMIT NO. 348

STOCKTON SERVICES
PO BOX 1306
HAMPTON, NH 03842

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure.
(RSA 149-E:3-b)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal systems. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (WS 410.05)

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES
IN PLANS AS INDICATED BY BELOW CONDITIONS

WAIVER APPROVED LEACHFIELD TO BE 6' ABOVE IMPERVIOUS LAYER.

CORRECTED TO SHOW PROPER LOT NO. 2.

WBS 1/4/89

Approved this date: 11/02/88

By:

LOUIS SIROY

N.H. Water Supply & Pollution Control
Division Staff

(OVER)

APPLICANT'S

PERC TEST

DATE: 11/3/87

DEPTH OF HOLE: 28"

RATE OF PERC: 2 MIN/IN

DESIGN LOADING: 3 BEDROOMS

AREA REQUIRED: 560 SQ. FT.

PROPOSED SYSTEM: 20 x 30 FOR
600 SQ. FT. AREA PROVIDED

PLAN OF PROPOSED SEPTIC SYSTEM

LOCUS: LOT 2 ROUTE 150
KENSINGTON, NH



OWNER: ARMAND J. ROY
c/o GORSKI ASSOC
P.O. BOX 563, EXETER NH 03833

APPLICANT: STOCKTON SERVICES
P.O. BOX 1306
HAMPTON, N.H. 03842
DESIGNER PERMIT #348

DATE: 10/22/88

APPROVAL:

105



600'±
TO
WILD
PASTURE
RD
92
1 PIN